



**CERT**

# DVGW type examination certificate

## DVGW-Baumusterprüfzertifikat

**DG-5131DO0077**

Registration Number  
Registriernummer

<b>Field of Application</b> <i>Anwendungsbereich</i>	products of gas supply <i>Produkte der Gasversorgung</i>
<b>Owner of Certificate</b> <i>Zertifikatinhaber</i>	DiaCom Corporation 5 Howe Drive, USA- Amherst, NH 03031
<b>Distributor</b> <i>Vertreiber</i>	DiaCom Corporation 5 Howe Drive, USA- Amherst, NH 03031
<b>Product Category</b> <i>Produktart</i>	Greasing and sealing materials: Materials for membranes for gas appliances and equipment, not reinforced (5131)
<b>Product description</b> <i>Produktbezeichnung</i>	Ozone-resistant materials for membranes for gas appliances and equipment, not reinforced
<b>Model</b> <i>Modell</i>	EG-5516-B
<b>Test reports</b> <i>Prüfberichte</i>	Type testing: 22-00507-AB01 from 14.03.2023 (EBI)
<b>Test basis</b> <i>Prüfgrundlagen</i>	DIN EN 549 (01.09.2019)

**Date of Expiry / File No.** 14.03.2028 / 23-0172-GNE  
**Ablaufdatum / Aktenzeichen**

70028-04-A-DE

12.04.2023 Kir A-1/2

Date, Issued by, Sheet, Head of Certification Body  
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle



DVGW CERT GmbH  
Zertifizierungsstelle

Josef-Wirmer-Str. 1-3  
53123 Bonn

Tel. +49 228 91 88 - 888  
Fax +49 228 91 88 - 993

www.dvgw-cert.com  
info@dvgw-cert.com

<b>Type</b>	<b>Technical Data</b>	<b>Remarks</b>
<i>Typ</i>	<i>Technische Daten</i>	<i>Bemerkungen</i>
EG-5516-B	Hardness classification : H2 Temperature range: -20...+80 °C Temperature class: B2	

